

Notice for Fire Audit of Building or Premises

(Under section- 33 and 43(1) of Bihar Fire Service Act. 2014. under rule-22 (a) of Bihar Fire Service Rules. 2021)

**Office of the State Fire Officer-cum-Director, Bihar, Patna. Office of the Fire Station
(Authorized Officer) Chapra**

Letter no.- 66

Date- 10/02/2025

To,

SARASWATI SHISHU VIDYA
MANDIR,
SARASWATI SHISHU VIDYA
MANDIR DARSHAN NAGAR
CHAPRA PIN-841301,
Saran, BIHAR

Sub:- Notice for fire audit of the building or premises.

Sir,

With respect to the above mentioned reference and subject, it is to say that-

- (1) There are **0** basements and **4** floors in your building / premises.
- (2) The fire audit of the building! premises is necessary for verification of adequacy/inadequacy of the fire prevention and fire safety measures for the safety of life and property from fire disaster.
- (3) Under rule-22(a) of Bihar Fire Service Rules, 2021 under section 33 and 43(1) of Bihar Fire Service Act, 2014, the power for fire audit is conferred, for ensuring the fire prevention and fire safety measures, after entering in any type of building or premises between sunrise to sunset, after notice of 3 hours or at any time without notice in case of thinking of urgency.

That is why, the fire audit of your building/premises will be done on date **10/02/2025** at **03:00 PM** hours under the above mentioned conferred powers. Please, will remain/present for fire audit yourself /vide your representative with necessary documents.

This electronically generated and does not require any signature.

ज्ञापांक 1109 / फा0 सं0 17 2024

कार्यालय अग्निशामालय पदाधिकारी, छपरा (सारण)

दिनांक 29/12/2024।

सुभा में,

प्रबंधक,

अग्निशामालय विद्युत विभाग केन्द्र छपरा (सारण)

विषय:- अग्निशामक यंत्रों की जाँच प्रतिवेदन प्रमाण-पत्र निर्गत करने के संबंध में।

महोदय,


उपर्युक्त विषय के आलोक में कहना है कि आपके संस्था का दिनांक 25/12/2024 को अग्निशामन पदाधिकारी, छपरा द्वारा आपके रकून कि जाँच की गई जिसमें निम्न अग्निशामक यंत्र सही अवस्था में पाया गया जिनका संचारण IS2190/1997 के अनुरूप है।

- | | |
|--------------------------|------------------|
| 1. ए0 बी0 सी0 टाईप 06 | (61) (6 kg) अदद |
| 2. बी0 सी0 टाईप 02 | (7) (9 kg) अदद |
| 3. मेकेनिकल फोम 02 | (7) (9 kg) अदद |
| 4. सी0 ओ0 टु0 01 | (8) (4.5 kg) अदद |
| 5. बालू पानी (बाल्टी) 06 | (61) अदद |
| 6. कम्बल 08 | (71/6) अदद |
| 7. स्टैटिक टैंक 5000 LT | (फॉन एक्जाम्पल) |

उपर्युक्त अग्निशामक यंत्र का रिफिल मेंट हॉल डिस्ट्रिक्ट कन्टेनर सही अवस्था में पाया गया। प्रबंधक को निर्देश दिया जाता है कि अग्निशामक यंत्रों को निर्देशित स्थान पर रखेंगे एवं समयानुसार रिफिलिंग कराते रहेंगे एवं वर्ष में दो बार एक्जिट फायर ड्रिल एवं मौक ड्रिल करवायेंगे। निर्देश दिया जाता है कि भवन निर्माण में नेशनल बिल्डिंग कोड ऑफ इंडिया पार्ट-4 फायर एण्ड लाईफ सेफ्टी में वर्णित प्रावधानों के अनुसार अन्य व्यवस्था सुनिश्चित कर लेंगे।

अतः वर्ष दिसम्बर 2024 ई0 तक रकून संचालन हेतु अग्निशामक यंत्रों का प्रमाण-पत्र निर्गत की जाती है। पुनः समय पर अग्निशामक उपकरणों का संबंधित कार्यालय से जाँच करा लेंगे।

नोट:- निरीक्षण के दौरान उपकरणों को खराब पाये जाने की स्थिति में जाँच प्रतिवेदन नवीकरण को जाँच में भी रद्द करने की अनुशंसा की जा सकती है।


अग्निशामन पदाधिकारी
अग्निशामालय पदाधिकारी
छपरा (सारण)